

Secretary of State
Filing Data

**For Filing Administrative
Regulations**

For Emergency
Regulations Only

Effective Date

Expiration Date

Governor's Signature

State Environmental Commission

Classification Proposed Adopted By Agency Temporary Emergency Permanent

Permanent Regulation R148-09: Revision to Air Emissions Limits at NV Energy's Reid-Gardner Generating Station: This regulation revises the requirement for sulfur dioxide (SO₂) emission limits at NV Energy's Reid Gardner [electrical power] Generating Station, located in the California Wash northeast of Las Vegas. The regulation lowers the emission limits from 0.25 lb/10⁶ Btu to 0.15 lb/10⁶ Btu, on a 24-hour average, for units 1, 2 and 3. This limit becomes effective on January 1, 2015 or 5 years after approval of Nevada's regional haze state implementation plan by the U.S. Environmental Protection Agency (EPA), whichever occurs first.

Authority citation other than 233B: §1, NRS 445B.210

Notice date: November 6, 2009

Hearing date: December 9, 2009