



CHAIRMAN:
Melvin D. Close
Las Vegas, NV

VICE CHAIRMAN:
Alan Coyner
Administrator
Division of Minerals
Commission on Mineral
Resources

MEMBERS

Pete Anderson
State Forester
Division of Forestry

Terry Crawforth
Director Department of
Wildlife

Lew Dodgion
Carson City, NV

Don Henderson
Director Department of
Agriculture

Ira Rackley
Las Vegas, NV

Hugh Ricci
State Engineer
Division of Water Resources

Harry Shull
Las Vegas, NV

Frances Sponer
State Board of Health
Las Vegas, Nevada

Stephanne Zimmerman
Las Vegas, NV

COUNSEL
David Newton

STAFF
[John B. Walker](#)
Executive Secretary

PUBLIC NOTICE - April 1, 2006

Pursuant to regulation LCB File No. R036-05, which was adopted by the State Environmental Commission (SEC) on October 4, 2005, (see: <http://www.sec.nv.gov/main/hearing1005.htm>) the SEC would like to notify the public that sections 1, 2 and 4 of that regulation become effective as of April 1, 2006.

Section 4 of the regulation repeals Nevada Administrative Code (NAC) 445B.22023, and sections 1 and 2 simply remove references from other sections in Chapter 445B of the NAC to the section that is being deleted. NAC 445B.22023 reads:

NAC 445B.22023 visible emissions: Coal-fired steam generating facilities. ([NRS 445B.210](#))

1. The provisions of this section and [NAC 445B.22017](#) and [445B.2202](#) apply to any coal-fired steam generating facility used to produce electricity with an equipment manufacturer's guarantee or demonstrated capability of more than 7,936 x 10⁶ Btu (2,000 x 10⁶ kg-cal) per hour of heat input which existed before 1972.

2. Each coal-fired steam generating unit at a facility must not discharge any particulate matter which exceeds an average opacity of 30 percent for any 6-minute period contained in any hour as measured in the emissions stack of the facility in the manner described in subsection 3.

3. The opacity of the particulate matter must be averaged over each 6-minute period and recorded 10 times per hour. The initial 6-minute period for each hour must begin on the hour. The average opacity for each 6-minute period must be recorded after the expiration of that period.

4. During the interim compliance period specified in 40 C.F.R. § 52.1488(d), each coal-fired steam generating unit at a facility must comply with the opacity provisions of 40 C.F.R. § 52.1488(d).

[Environmental Comm'n, Air Quality Reg. §§ 4.5 & 4.5.1, eff. 8-28-79]—(NAC A 9-19-90; 10-29-93; 10-29-93, eff. 4-1-94; R198-03, 4-26-2004)

There are no coal-fired steam generating facilities in Nevada to which this section applies, and the regulation is therefore obsolete.